

APRIL 2023

JAMAICA PUBLIC SERVICE COMPANY, LTD.

REQUEST FOR THE SUPPLY OF

**TWO (2) 38KV VACUUM
CIRCUIT BREAKER
(TO BE USED WITH CAPACITOR BANKS).**

ADDENDUM #1. Q & A Response

KOLONJE MCKENZIE
BUYER-PURCHASING AND CUSTOMS
JAMAICA PUBLIC SERVICE COMPANY LIMITED

Question and Answers.

1. On page TS-13, under the Ratings section, there are two of the ratings that seem to be backwards. Can you confirm that the “Nominal System Voltage” of 38 kV and the “Rated Maximum Voltage” of 25.8 kV in this file are indeed correct please?

Answer: Nominal System voltage-25.8kV
 Rated Maximum Voltage- 38kV

ADDENDUM.

4.0 Submission of Bids and Selection Criteria

All responses must be in English Language. Your bid response must be presented in two (2) separate files namely Financial/Costing and Technical Specifications. The deadline for submission of bids is **11:59pm on Thursday May 25, 2023.**

RFP CALENDAR		
ACTIVITY	DUE DATE	RESPONSIBILITY
RFP date	April 25, 2023	JPS
Bidder submits questions on RFP	May 1, 2023	Bidder
Final date to respond to all queries	May 5, 2023	JPS
Bidder provide their intension to bid	May 10, 2023	Bidder
Completion of RFP and deadline for submission of bids to JPS	May 25, 2023	Bidder
Bid Opening	May 26, 2023	JPS

The Company may, at its discretion, extend this deadline for the

submission of bids, in which case all rights and obligations of the Company and Bidders previously subject to the deadline will thereafter be subject to the deadline as extended. The dates are subject to change on the RFP Calendar.

5.1 Opening of Bids by Purchaser

The Purchaser will open bids privately, on *Friday May 26, 2023*. At the following location:

Jamaica Public Service Company Limited
113 Washington Boulevard
Kingston 20
Jamaica, W.I.

7.6 Delivery and Shipment

a) Local suppliers

It is the responsibility of the Seller to obtain at their expense:

- all licenses
- customs formalities
- transport associated with the delivery of the goods to JPS

The Seller shall bear all risks of loss of or damage to the goods until such time as they have been delivered to JPS.

The Seller must provide the goods, the payment invoice and delivery slip in conformity with the contract and any other evidence of conformity; (example test certificates,) which may be required by the contract.

b) Overseas suppliers

The Supplier shall be entirely responsible for all taxes, duties, license fees, port charges and other such levies imposed by the country of origin. Goods will be delivered FOB Miami JPS Freight or CIF Kingston Jamaica in accordance with Incoterms 2020.

APPENDIX 2

TS.03.3 Ratings

The circuit breakers shall have the following ratings.

- Nominal system voltage	25.8-kV
- Type of circuit breaker	Vacuum
- Rated maximum voltage	38-kV
- Rated frequency	50 Hz
- Rated lightning impulse withstand level	200-kV
- Min. Continuous current	600 A or 1200A (as determined by designs)
- Short circuit interrupting current	25-kA
- Maximum interrupting time	5 cycles
- Rated control voltage	125 V dc