



JAMAICA PUBLIC SERVICE COMPANY, LIMITED

ALCAN T1 TRANSFORMER REPLACEMENT

REQUEST FOR PROPOSALS

ADDENDUM #2

The Supply of -

One (1) 6.0MVA, 69 – 3.45KV POWER TRANSFORMER

RFP # 966748

**Instructions to Bidders
General Conditions of Contract
Special Conditions of Contract
Exhibits
Bid Form
Technical Specifications
Schedules**

**December 2023
Purchasing and Customs Department
113 Washington Boulevard Kingston
JPS Co. Ltd., Jamaica**

IB.19 Deadline for Submission of Bids

IB.19.1 Bids must be received by the Purchaser at using the method specified under para. IB.18.1 no later than 11:59 pm Eastern Standard Time on January 11, 2024.

RFP CALENDAR		
ACTIVITY	DUE DATE	RESPONSIBILITY
RFP date	November 21, 2023	JPS
Bidder submits questions on RFP	November 30, 2023	Bidder
Final date to respond to all queries	December 18, 2023	JPS
Bidders provide their intention to bid	December 20, 2023	Bidder
Completion of RFP and deadline for submission of bids to JPS	January 11, 2024	Bidder
Bid Opening	January 12, 2024	JPS

Note below Technical changes. No Fan is required for the Cooling and the connection should be Primary Delta, Secondary delta.

TS.03.4 Transformer Ratings

Rated Capacity		6.0 MVA
Temperature Rise		65°C above 40°C ambient
Cooling		ONAN (no Fan Required)
Rated Frequency		50 Hz
Rated Voltage	-high -Low	69 kV 3.45 kV
Connection	-	See table below
Vector Grouping	-	See table below
Rated Impedance Voltage not less at Base MVA		6.0 - 8.0%
BIL	-	See table below

Item	Rating	Connection	Vector Group	BIL
1	6.0 MVA 69 / 3.45 kV	Primary delta Secondary delta	Dd0	Primary 350KV Secondary 60KV