

JAMAICA PUBLIC SERVICE COMPANY, LTD.

PROTECTION PANEL PROCUREMENT FOR WASHINGTON BOULEVARD, HOPE & ROCKFORT SUBSTATIONS PANEL REPLACEMENT PROJECT

REQUEST FOR PROPOSALS

The Supply of -

PROTECTION PANELS INCLUDING

69kV Line Protection Panels
69/24kV Transformer Protection Panels,
Control Panels

RFP #967580

Addendum 1.

January 25, 2024
System Protection & Control Department
693A Spanish Town Road
JPS Co. Ltd., Kingston, Jamaica.

Questions and Answer:

1. In RFP #967580, there are models from SEL relays and MICOM relays. Would JPSCo accept all relays to be MICOM relays?

ANS. No. Our intention is to have our Primary protection relay model being different from our Backup protection relays, as per our request.

2. Please note we humbly request JPS clarify an important discrepancy between the JPS Instruction to Bidders, and, the Technical Specification regarding the “Scope” of the RFP. Please confirm if the RFP is for the three (3) Substation locations (Hope, Washington Blvd, and Rockfort) as noted in the Intro and in the Drawings submitted, or, just two (2) Substation locations (Hope and Washington Blvd) as noted in the Technical Spec.

ANS. RFP is three locations, Hope, Washington Blvd and Rockfort.

3. Does the Bid Requires a Bid bond?

ANS. No Bid security is required.

Addendum:

IB.18 Upload and Labeling of Bids

IB.18.1 Only Electronic submissions will be accepted, using ShareFile by Citrix. All uploads will be confidential.

- 1) Respondents must confirm their intention to bid by January 30, 2024, in order to be setup in JPS ShareFile folder.
- 2) Access to individual vendor folders will be given 1 weeks before the bid closes to eliminate any issues for bid upload by RFP deadline.
- 3) Files must be accurately labelled/named. Commercial Information must be a separate file from your Technical Proposal.
- 4) ShareFile Access will be removed when the bid closes.

Additional information on this software can be accessed by clicking the links below:

- Basic Client Guide
<https://citrix.sharefile.com/share/view/s1bff52f8d434781a>
- **Training (video)** <https://www.sharefile.com/support/training>

IB.19 Deadline for Submission of Bids

- IB.19.1 Bids must be received by the Purchaser using the Method specified under para. IB.18.2 no later than 11:59 pm Jamaica Time on **Thursday, February 8, 2024.**

| RFP CALENDAR | | |
|--|-------------------|-----------------------|
| ACTIVITY | DUE DATE | RESPONSIBILITY |
| RFP date | December 29, 2023 | JPS |
| | | |
| RFP Confirmation of receipt date | January 2, 2024 | Bidder |
| | | |
| Bidder submits questions on RFP | January 9, 2024 | Bidder |
| | | |
| Final date to respond to all queries | January 16, 2024 | JPS |
| | | |
| Bidder Submit their intention to Bid | January 30,2024 | Bidder |
| | | |
| Completion of RFP and deadline for submission of bids to JPS | February 8, 2024 | Bidder |
| | | |
| Bid Opening | February 9, 2024 | JPS |

TS.01.2 Location

Substation sites are located as follows:

- Hope substation – Old Hope Road, Kingston
- Washington Boulevard – Washington Boulevard, Kingston
- Rockfort substation- Windward road, Kingston