



JAMAICA PUBLIC SERVICE COMPANY, LTD.

REQUEST FOR PROPOSALS

The Supply of -

**ONE 80/100 MVA, 138 – 69kV INTERBUS TRANSFORMER FOR
THREE MILES SUBSTATION 138kV EXPANSION PROJECT**

RFP # 1027661

Question and Answer, Addendum #1

**August 2025
Engineering & Standards Department
693A Spanish Town Road
JPS Co. Ltd., Kingston, Jamaica.**

Question and Answers

1. Reference Documentation / Photos

Would it be possible for you to share:

- Any photos of existing 138/69 kV interbus transformers currently installed in Jamaica (for general reference), and/or
- A datasheet from a previously accepted or installed transformer of similar specification?

Response: [It is not possible for us to share any photos or datasheet of existing 138/69 kV interbus transformers currently installed in Jamaica.](#)

2. Transformer Loss Standard

Could you kindly clarify whether the transformer loss requirements must comply with **EU Commission Regulation (EU) 2019/1783**?

We did not see a specific loss standard referenced in the tender documentation and would like to ensure our proposal meets all applicable requirements.

Response: [Transformer losses calculations and requirements shall be as per IEEE C57.12 series of standards.](#)

3. What is the expected delivery time for this equipment?

Response: [As per the delivery time outline in the RFP document.](#)

4. What is the timeline for this opportunity? What is the expected award date? What is the stage of this opportunity?

Response: [It's in the planning stage for approval.](#)

5. Please confirm if the transformer will be a replacement, if so, please share the nameplate of the transformer in site?

Response: [Not a replacement](#)

6. Are there any dimensional restrictions?

Response: [As per specification](#)

7. Please confirm if that transformer will work on parallel with another in the substation.

Response: [No. Vector group and voltage shall be as per spec.](#)

Addendum

IB.19 Deadline for Submission of Bids

IB.19.1 Bids must be received by the Purchaser at the address specified under para. IB.18.2 no later than 11:59 pm Eastern Standard Time on **Thursday, August 28, 2025.**

RFP CALENDAR		
ACTIVITY	DUE DATE	RESPONSIBILITY
RFP date	July 3, 2025	JPS
Bidder submits questions on RFP	July 11, 2025	Bidder
Final date to respond to all queries	July 18, 2025	JPS
Bidder Provide intension to Bid	August 15, 2025	Bidder
Completion of RFP and deadline for submission of bids to JPS	August 28, 2025	Bidder
Bid Opening	August 29, 2025	JPS