



April 30th, 2026

ADDENDUM 2- JPS RFP # 1065948
Replacement Frame 6B Casing

The purpose of this addendum is to provide responses to questions and requests received in relation to this RFP. Please see the queries submitted and JPS' responses below:

1. **Query:**

We have noted requirement for Hydrostatic testing to be carried out on both new and used casings.

[we] can confirm that we DO NOT include hydrostatic testing as a requirement on our manufacturing supply chain

We trust that Hydrostatic testing is not a mandatory requirement, can this be confirmed

JPS Response:

Hydrostatic testing is not mandatory.

2. **Query:**

We note that Stage 2 and Stage 3 shrouds are listed under a separate Model List and would therefore not be included in the scope of supply. However, we are unable to identify any reference to Stage 1 shrouds. Kindly confirm whether these should be included and, if so, provide the applicable part number.

JPS Response:

No shrouds or associated locking hardware are required to be supplied with the turbine casing.

2. **Query:**

We request a two (2)-week extension to the bid submission deadline of May 15, as a replacement casing constitutes an upgrade requiring additional engineering review. This would result in a revised submission date of May 29.

JPS Response:

Extension granted.

DIRECTORS:

DAMIAN OBIGLIO (CHAIRMAN)

NADANI CHUNG

MINNA ISRAEL, C.D., LLD (Hon.)

HON. CHARLES JOHNSTON, O.J., C.D

SANGHO LEE

MOHAMED MAJEED

DENNIS MORGAN

HA KYOUNG SONG

HON. DANVILLE WALKER, O.J., J.P.

JAMAICA PUBLIC SERVICE
COMPANY LIMITED

6 KNUTSFORD BOULEVARD
KINGSTON 5, JAMAICA

T: (876) 926.3190-9

F: (876) 936.1800

www.jpSCO.com



Revised Submission Deadline:

The deadline for submission of proposals in response to this RFP has been revised as follows:

- **11:59 p.m. (Jamaica Local Time) on Friday, May 29, 2026**

All other terms and conditions of the RFP remain unchanged. Kindly and ensure that your proposal reflects the information provided herein.

[END OF DOCUMENT]